



Danfoss Drives A/S

Ulsnæs 1
DK-6300 Graasten
Denmark
Reg.No.: 233981

Telephone: +45 7488 2222
Telefax: +45 7465 2580

E-mail: FNI@Danfoss.com
Homepage: www.danfoss.com

Your ref.

Our ref.
501G1029

Date
2001-05-28

Direct dialling
+45 7488 4615

Declaration for VLT 5000® Series Frequency Converter.

This is to certify that the below listed Danfoss products will continue to fulfil specifications in accordance with Danfoss' contractual obligations when exposed to the listed mains voltages.

Product	Mains voltage	Warning limits		Trip limit
		Voltage warning low	Voltage warning high	Overvoltage
VLT® 5002-5062	3 x 342-550 V	310 V \pm 2,5%	585 V \pm 2,5%	605 V \pm 5%
VLT® 5060-5500	3 x 342-550 V	310 V \pm 2,5%	585 V \pm 2,5%	605 V \pm 5%

The products are designed and tested to the above listed mains voltages without giving voltage warning or trip. The products will give a voltage warning at the above warning limits. The intermediate circuit will trip without further warning at the above trip limit.

The VLT 5000® Series, purchased before the release of the new manual, will operate to the above listed mains voltage.

The above listed voltages are measured by the drive during operation and the motor running in motoric mode. Deviations from voltages measured with other instruments may occur.

Issued by:

Flemming Lynge Nielsen
Quality Assurance Manager